


**PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION  
CERTIFICATE.**

No. 134Date: 06/03/2023

It is certified that an inspection team headed by Archana Shrivastava  
& Anita Jayant (Chemist) (Name of Officers  
with designation) from Public Health Engineering Dept. Gwalior (Name of  
Department/Office) inspected the BHARTIYAM VIDYA NIKETAN  
SCHOOL GWALIOR (Name & Address of  
the School) on 06/03/2023 and found that the BHARTIYAM VIDYA NIKETAN  
SCHOOL GWALIOR (Name of school) has safe  
drinking water facilities for the students and members of staff of the institution and is maintaining  
the hygienic sanitation condition in the school building & the campus as per the norms  
prescribed by the Central/State/U.T Govt.

The above valid for a period of One Year.Signature with Seal: 

Name

: Archana Shrivastava  
CHEMIST  
Director Water Testing Lab  
PHE Division Gwalior

Designation

: CHEMIST

To


The PRINCIPAL  
BHARTIYAM VIDYA NIKETAN  
SCHOOL GWALIOR

  
Principal  
Bhartiyam Vidya Niketan  
Gwalior

(Name &amp; Address of the Institution)

  
Manager  
Bhartiyam Vidya Niketan



  
अध्यक्ष  
देवीबाई शिक्षा एवं समाज कल्याण  
समिति, ग्वालियर

**Public Health Engineering Department District Water-  
Testing Laboratory Gwalior**  
**Test Report**

Type of sample: Water Sample		Particular of sample : collected / not collected by PHED	
Particular of sender: Principal Bhartiya Vidya Niketan Gwalior (M.P.)			
Sample No.	Place of Collection and Details of Sample	Date of collection	
1	Drinking water	01-03-2023	
2	-	-	
3	-	-	
4	-	-	
Particular of Sample :			
Date of Receipt: 01-03-2023		Time of Receipt: 01:30 PM	
Lab Reference No:		Date of Analysis: 03-03-2022	

Nature of Study – Chemical and Bacteriological Analysis

S.N.	Characteristics	Unit	As Per BIS-10500-2012 For Drinking Water		RESULT			
			Acceptable Value	Permissible limit in the absence of alternate source	Sample 1	Sample 2	Sample 3	Sample 4
<b>PHYSICAL TESTE</b>								
1	Turbidity	NTU	1.0	5.0	01	-	-	-
2	Color	Cobalt	5	15	-	-	-	-
3	Taste & Odour		Unobjectionable	Objectionable	Unobjectionable	-	-	-
4	Temperature	C°	-	-	-	-	-	-
<b>CHEMICAL TESTE</b>								
5	PH Value	PH Scale	6.5 To 8.5	No Relaxation	7.0	-	-	-
6	Alkalinity	Mg/L	200	600	78	-	-	-
7	Chlorides (as Cl)	Mg/L	250	1000	42	-	-	-
8	Nitrate as No3	Mg/L	45	45	1.1	-	-	-
9	Total hardness	Mg/L	200	600	60	-	-	-
10	Calcium as Ca	Mg/L	75	200	16	-	-	-
11	Magnesium as mg	Mg/L	30	100	4.8	-	-	-
12	iron	Mg/L	0.3	1.0	0.10	-	-	-
13	Free Chlorine	Mg/L	0.2	1.0	-	-	-	-
14	T.D.S.	Mg/L	500	2000	120	-	-	-
15	Fluoride	Mg/L	1.0	1.5	0.10	-	-	-
16	Sulphate sa SO4	Mg/L	200	400	04	-	-	-
<b>BECT. FEACAL TESTE</b>								
17	MPN of coliform	per 100 ml	Nil		-	-	-	-
18	Faecal Coliform	Per 100 ml	Nil		Nil	-	-	-


- This report should not be provided partially or fully without approval of signatory authorities for legal purposes.
- It is Recommended that acceptable limit is to be implemented values in excess those mentioned under "Acceptable" render the water not suitable, but still may be tolerated in the absence of an alternative source, but up to the limits indicated under the "permissible limit in the absence of alternate Source"
- The results refer only to tested samples and parameters tested.
- samples will be stored for a period of 10 days from the date of issue of report.
- This Lab does not hold any responsibility for variation in results for samples kept on hold for want of clarification.


  
Signature of Analyst  
District Lab Gwalior

  
Lab Incharge  
P.H.E. Division Gwalior (M.P.)  
P.H.E. Division, Gwalior (M.P)

No. 134 /PHED/ Date :- 06/03/2023

  
Manager  
Bhartiyam Vidya Niketan

  
Principal  
Bhartiyam Vidya Niketan  
Gwalior

  
अध्यक्ष  
देवीबाई शिक्षा एवं समाज कल्याण  
समिति, ग्वालियर

