Annexure- C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 472 Dated: 30/10/2026

It is certified that an inspection team headed by

Smt. Anita Jayant Chemist PHED Gwalior

(Name of Officers with designation)

from Smt. Archna Shrivastava Chemist PHED inspected the **Bhartiyam Vidya Niketan School, Chirvayi Naka, Shivpuri Link Road, Gwalior** on 29/10/2026 and on the basis of **Water Test Report** (Attached) bearing no. 472 dated 30/10/2026 of District water testing Lab (PHED Lab) Gwalior certified that the **Bhartiyam Vidya Niketan** has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till one year [30/10/2026 to 29/10/2027]

Signature with Seal: for Lab Incharge
District Water Testing Laboratory
PHE Division, Gwalior (M.P

Name: Smt. Anita Jayant

Designation: Chemist

Name & Address of the Office / Department: PHED Gwalior

To

Bhartiyam Vidya Niketan,

Chirvayi Naka,

Shivpuri Link Road, Gwalior-474001

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

Public Health Engineering Department District Water- Testing Laboratory Gwalior

Test Report

Type of sample: Water Sample	Particular of sample : collected / not collected by PHED

Particular of sender:- : Principal Bhartiyam Vidya Niketan Chirvayi Naka Shivpuri Link Road Gwalior (M.P.)

Sample No.	Place of Collection and Details of Sample	Date of collection
1	Drinking Water	27.10.2026
2	-	-
3	-	-
4	-	-

Particular of Sample :

Date of Receipt:	Time of Receipt:12:46PM
Lab Reference No:	Date of Analysis: 28.10.2026

Nature of Study – Chemical and Bacteriological Analysis

S.N.	Characteristics	Unit	As Per BIS-10500-2012 For Drinking Water		RESULT			
			Acceptable Value	Permissible limit in the absence of alternate source	Sample 1	Sample 2	Sample 3	Sample 4
PHYSICAL TEST								
1	Turbidity	NTU	1.0	5.0	1.2	-	-	-
2	Color	Cobalt	5	15	-	-	-	-
3	Taste & Odour		Unobjectionable	Objectionable	Unobjectionable	-	-	-
4	Temperature	C°	-	-	-	-	-	-
CHEMICAL TEST								
5	PH Value	PH Scale	6.5 To 8.5	No Relaxation	7.1	-	-	-
6	Alkalinity	Mg/L	200	600	78	-	-	-
7	Chlorides (as Cl)	Mg/L	250	1000	46	-	-	-
8	Nitrate as No3	Mg/L	45	45	2.4	-	-	-
9	Total hardness	Mg/L	200	600	94	-	-	-
10	Calcium as Ca	Mg/L	75	200	24	-	-	-
11	Magnesium as mg	Mg/L	30	100	14	-	-	-
12	Iron	Mg/L	0.3	1.0	0.10	-	-	-
13	Free Chlorine	Mg/L	0.2	1.0	0.0	-	-	-
14	T.D.S.	Mg/L	500	2000	180	-	-	-
15	Fluoride	Mg/L	1.0	1.5	0.11	-	-	-
16	Sulphate sa SO4	Mg/L	200	400	05	-	-	-
BECT. FEACAL TEST								
17	Total Coliform	per 100 ml	Nil		Nil	-	-	-
18	E Coli or Thermo tolerant coliforms	Per 100 ml	Nil		Nil	-	-	-

- This report should not be provided partially or fully without approval of signatory authorities for legal purposes.
- It is Recommended that acceptable limit is to be implemented values in excess those mentioned under " Acceptable" render the water not suitable, but still may be tolerated in the absence of an alternative source, but up to the limits indicated under the "permissible limit in the absence of alternate Source"
- The results refer only to TEST samples and parameters TEST.
- Samples will be stored for a period of 10 days from the date of issue of report.
- This Lab does not hold any responsibility for variation in results for samples kept on hold for want of clarification.

Signature of Analyst
District Lab Gwalior

for Lab In Charge
P.H.E. Division Gwalior (M.P.)

No. 472 /PHED/ Date :- 30/10/2026

1/1

-------End of Report------